



# 1 TEST CERTIFICATION

**Product:** HMI (Human Machine Interface)

**Model:** MT8121iE; MT612iE

**Brand:** Weintek; WeinView; EasyView

**Applicant:** **Weintek Labs., Inc.**  
3F, No. 910, Zhongzheng Rd., Zhonghe Dist.,  
New Taipei City, Taiwan

**Manufacturer:** **Weintek Labs., Inc.**  
3F, No. 910, Zhongzheng Rd., Zhonghe Dist.,  
New Taipei City, Taiwan


**Tested:** October 7, 2013 ~ October 9, 2013

<b>Applicable Standards:</b>	<b>EN 55022: 2010, Class A</b>	<b>EN 55024: 2010</b>
	<b>CISPR 22: 2008 (Ed 6.0)</b>	IEC 61000-4-2: 2008
	<b>AS/NZS CISPR 22: 2009 with Amdt 1 (2010)</b>	IEC 61000-4-3: 2006 + A1: 2007 + A2: 2010
	<b>EN 61000-3-2: 2006 + A1: 2009 + A2: 2009</b>	IEC 61000-4-4: 2012
	<b>EN 61000-3-3: 2008</b>	IEC 61000-4-5: 2005
		IEC 61000-4-6: 2008
		IEC 61000-4-8: 2009
		IEC 61000-4-11: 2004

Deviation from Applicable Standard
None

The above equipment was tested by Compliance Certification Services Inc. for compliance with the requirements of technical standards specified above under the EMC Directive 2004/108/EC. The results of testing in this report apply only to the product/system, which was tested. Other similar equipment will not necessarily produce the same results due to production tolerance and measurement uncertainties.


**Approved by:**



---

Sam Hu  
Assistant Manager

**Reviewed by:**



---

Vesta Hsu  
Supervisor of report document dept.